

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08925**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 7/18/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-WC-1 Cafeteria Left

Collect Date: 06/02/2016
Collect Time: 06:08
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	HSN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08926**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-WC-2 Cafeteria Right

Collect Date: 06/02/2016
Collect Time: 06:09
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08927**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-KH-3 Kitchen Sink Left

Collect Date: 06/02/2016
Collect Time: 06:10
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08928**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-KC-4 Kitchen Sink Left

Collect Date: 06/02/2016
Collect Time: 06:12
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.010	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group

573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1

Sample ID: AW08929
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-KH-5 Kitchen Sink Right

Collect Date: 06/02/2016
Collect Time: 06:13
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Table with 8 columns: Test, Result, MCL, Qualifiers, Units, Method Used, Analyst, Analysis Date. Row 1: Lead, 0.007, 0.015, mg/L, SM3113B, MN, 8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
T Temperature outside specifications
S(+/-) Lab control sample outside acceptance limits
(+ Result may be biased high / - Result may be biased low)
R Duplication outside acceptance limits
A Sample contained air bubble or headspace
M(+/-) Matrix spike recovery outside acceptance limits
H Hold time exceeded
B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.

Handwritten signature of John Wilson

John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08930**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-KC-6 Kitchen Sink Right

Collect Date: 06/02/2016
Collect Time: 06:13
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.005	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08931**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-0-WC-7 Outside Room 90

Collect Date: 06/02/2016
Collect Time: 06:46
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08932**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-8 Outside Room 114 Water Foutain

Collect Date: 06/02/2016
Collect Time: 06:44
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08933**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-9 Outside Room 114 Water Bottle

Collect Date: 06/02/2016
Collect Time: 06:45
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08937**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-10 Outside House Left

Collect Date: 06/02/2016
Collect Time: 06:41
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08938**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-11 Outside House Right

Collect Date: 06/02/2016
Collect Time: 06:40
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08939**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-FH-12 Staffhouse 119

Collect Date: 06/02/2016
Collect Time: 06:42
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08941**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-FC-13 Staff Lounge 119

Collect Date: 06/02/2016
Collect Time: 06:43
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08942**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-NH-14 Nurse Near Door

Collect Date: 06/02/2016
Collect Time: 06:38
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08943**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-NC-15 Nurse Near Door

Collect Date: 06/02/2016
Collect Time: 06:39
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08945**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-DW-18 Room 128

Collect Date: 06/02/2016
Collect Time: 06:25
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.006	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08946**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-19 Outside Room 128

Collect Date: 06/02/2016
Collect Time: 06:24
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08947**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-20 Multipurpose Room Right

Collect Date: 06/02/2016
Collect Time: 06:28
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08948**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-1-WC-21 Multipurpose Room Left

Collect Date: 06/02/2016
Collect Time: 06:29
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08950**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-2-WC-22 Outside Room 224 Right

Collect Date: 06/02/2016
Collect Time: 06:31
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.004	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08951**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/19/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-2-WC-23 Outside Room 224 Left

Collect Date: 06/02/2016
Collect Time: 06:32
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.003	0.015		mg/L	SM3113B	MN	8/11/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08952**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-2-WC-24 Outside Room 216

Collect Date: 06/02/2016
Collect Time: 06:35
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Needham Risk Management Resource Group
573 Columbia Turnpike
STE 3
East Greenbush ,NY 12061

Printed On : 8/19/2016 Page 1 of 1
Sample ID: **AW08953**
Date Received: 06/03/2016
Time Received: 14:19
Date Finalized: 8/1/2016
PO Number: GREENVILLE CSD
Your Ref: Scott M Ellis Elem

Customer: Needham Risk Management Resource Group
Owner: Greenville
Sample Loc: 11219 NY 32 Greenville NY
Sample Pt: GE-2-WC-25 Outside Room 207 Water Fount.

Collect Date: 06/02/2016
Collect Time: 06:35
Collected by: D. BAUER - J. MARTIN
Receipt Temp: 24 C see note 1

Water Source: Purchased PWS
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	<0.001	0.015	S+	mg/L	SM3113B	MN	7/16/2016

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- S(+/-) Lab control sample outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- M(+/-) Matrix spike recovery outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported
MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Instrument Performance Check (IPC) was above control limits. All other quality control parameters were within acceptable limits. Result unaffected by the high bias.

Test procedures for all analyses meet NELAC requirements unless noted.



John Wilson
Environmental Laboratory Supervisor and contact person
If you have questions, please call.
(518) 525-5480 / 5479

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.